




Utility Conflict Report

OWNER	Utility	SAWS	Corridor	SW MILITARY	SITE PHOTOS	
	Contact	ANN PECHE	ID	3153		
GENERAL INFO	Utility	WATER				
	Size and Material	STANDARD WATER METER, STEEL				
	Accessible Route	ASSET IS OUTSIDE ACCESSIBLE ROUTE				
	Longitudinal or Crossing	CROSSING				
	Placement Relative to ROW	INSIDE ROW				
LOCATION	Sheet No.	144				
	Station	595+22.45				
	Offset	22.29				
	Latitude	+29.356492				
	Longitude	-98.53992				
SUE	Level of Investigation Req'd	NONE				
	Test Hole No	N/A				
	Test Hole Depth	N/A				
RESOLUTION	Recommended Action	NO CONFLICT				
	Estimated Resolution Date					
	Resolution Status	NO RESOLUTION WAS REQUIRED				
	Comment	Top of meter to surface = 5 1/2" Lid flange thickness = 1/2" Total lid thickness = 2" Sidewalk width = 5'-0" Meter to front of sidewalk = 3'-0" Vertical difference between top of lid and top of sidewalk = 10"-12"				
Date Collected		7/31/2018 11:28:39 AM	Date Modified		11/28/2018 6:59:12 AM	

TBPE Firm Registration #470 | TBPLS Firm Registration #10028800