

## Utility Conflict Report

<b>OWNER</b>	<b>Utility</b>	SAWS	<b>Corridor</b>	SW MILITARY	<b>SITE PHOTOS</b>
	<b>Contact</b>	ANN PECHE	<b>ID</b>	4174	
<b>GENERAL INFO</b>	<b>Utility</b>	WATER			
	<b>Size and Material</b>	STANDARD WATER METER, CAST IRON			
	<b>Accessible Route</b>	ASSET IS OUTSIDE ACCESSIBLE ROUTE			
	<b>Longitudinal or Crossing</b>	CROSSING			
	<b>Placement Relative to ROW</b>	INSIDE ROW			
<b>LOCATION</b>	<b>Sheet No.</b>				
	<b>Station</b>	694+20.39			
	<b>Offset</b>	20.8622			
	<b>Latitude</b>	+29.356649			
	<b>Longitude</b>	-98.50887			
<b>SUE</b>	<b>Level of Investigation Req'd</b>	NONE			
	<b>Test Hole No</b>	N/A			
	<b>Test Hole Depth</b>	N/A			
<b>RESOLUTION</b>	<b>Recommended Action</b>	NO CONFLICT			
	<b>Estimated Resolution Date</b>				
	<b>Resolution Status</b>	NO RESOLUTION WAS REQUIRED			
	<b>Comment</b>	Back of sidewalk to meter = 1'-2" Sidewalk width = 6'-0" Top of meter to surface = 1" Lid flange thickness = 3/8" Total lid thickness = 1 3/4"			
<b>Date Collected</b> 8/2/2018 12:32:24 PM <b>Date Modified</b> 11/28/2018 6:59:12 AM					

